

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 13)**

Water Level of the accumulated water (at 7:00 on November 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,007 mm (54 mm increase since 7:00 on November 12)	O.P.+ 2,514 mm (21 mm decrease since 7:00 on November 12)	—
	Water level of Turbine Building	O.P.+ 2,914 mm (20 mm increase since 7:00 on November 12)	O.P.+ 3,004 mm (65 mm increase since 7:00 on November 12)	O.P.+ 2,668 mm (17 mm decrease since 7:00 on November 12)	O.P.+ 2,712 mm (19 mm decrease since 7:00 on November 12)
	Water level of Reactor Building	O.P.+ 4,529 mm (9 mm increase since 7:00 on November 12)	O.P.+ 3,065 mm (66 mm increase since 7:00 on November 12)	O.P.+ 2,671 mm (24 mm decrease since 7:00 on November 12)	O.P.+ 2,769 mm (17 mm decrease since 7:00 on November 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,063 mm (Increase from initial level:5,280 mm, 19 mm increase since 7:00 on November 12) O.P.+ 1,754 mm (Increase from initial level:2,480 mm, 197 mm decrease since 7:00 on November 12) O.P.+ 4,351 mm (Water level from floor:555 mm, 7 mm increase since 7:00 on November 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:33 on November 13 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 7:33 AM on November 13, we temporarily stopped the Second Cesium Adsorption Apparatus (SARRY) for vessel replacement.				

※ For quick publication of the data of water level, values are provided as reference values.