

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 17)**

Water Level of the accumulated water (at 7:00 on November 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,975 mm (11 mm decrease since 7:00 on November 16)	O.P.+ 2,483 mm (4 mm decrease since 7:00 on November 16)	—
	Water level of Turbine Building	O.P.+ 2,978 mm (15 mm increase since 7:00 on November 16)	O.P.+ 2,965 mm (14 mm decrease since 7:00 on November 16)	O.P.+ 2,684 mm (2 mm decrease since 7:00 on November 16)	O.P.+ 2,667 mm (6 mm decrease since 7:00 on November 16)
	Water level of Reactor Building	O.P.+ 4,535 mm (1 mm decrease since 7:00 on November 16)	O.P.+ 3,049 mm (9 mm decrease since 7:00 on November 16)	O.P.+ 2,677 mm (3 mm decrease since 7:00 on November 16)	O.P.+ 2,722 mm (7 mm decrease since 7:00 on November 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,119 mm (Increase from initial level:5,336 mm, 11 mm increase since 7:00 on November 16) O.P.+ 1,636 mm (Increase from initial level:2,362 mm, 101 mm decrease since 7:00 on November 16) O.P.+ 4,379 mm (Water level from floor:583 mm, 8 mm increase since 7:00 on November 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 15:07 on November 13)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:36 on November 13 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.