

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 18)**

Water Level of the accumulated water (at 7:00 on November 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,880 mm (95 mm decrease since 7:00 on November 17)	O.P.+ 2,479 mm (4 mm decrease since 7:00 on November 17)	—
	Water level of Turbine Building	O.P.+ 2,993 mm (15 mm increase since 7:00 on November 17)	O.P.+ 2,926 mm (39 mm decrease since 7:00 on November 17)	O.P.+ 2,680 mm (4 mm decrease since 7:00 on November 17)	O.P.+ 2,662 mm (5 mm decrease since 7:00 on November 17)
	Water level of Reactor Building	O.P.+ 4,534 mm (1 mm decrease since 7:00 on November 17)	O.P.+ 3,014 mm (35 mm decrease since 7:00 on November 17)	O.P.+ 2,677 mm (No change since 7:00 on November 17)	O.P.+ 2,717 mm (5 mm decrease since 7:00 on November 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,196 mm (Increase from initial level:5,413 mm, 77 mm increase since 7:00 on November 17) O.P.+ 1,542 mm (Increase from initial level:2,268 mm, 94 mm decrease since 7:00 on November 17) O.P.+ 4,385 mm (Water level from floor:589 mm, 6 mm increase since 7:00 on November 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 15:07 on November 13)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on November 17 to 15:00 on November 17)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:36 on November 13   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	From 9:39AM to 3:22PM   on Nov 17, transfer of accumulated water in Unit 2 Turbine Building basement was transferred to the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building).				

※ For quick publication of the data of water level, values are provided as reference values.