

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 21)**

Water Level of the accumulated water (at 7:00 on November 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,784 mm (26 mm decrease since 7:00 on November 20)	O.P.+ 2,498 mm (8 mm increase since 7:00 on November 20)	—
	Water level of Turbine Building	O.P.+ 2,766 mm (9 mm increase since 7:00 on November 20)	O.P.+ 2,820 mm (28 mm decrease since 7:00 on November 20)	O.P.+ 2,719 mm (8 mm increase since 7:00 on November 20)	O.P.+ 2,676 mm (9 mm increase since 7:00 on November 20)
	Water level of Reactor Building	O.P.+ 4,470 mm (52 mm decrease since 7:00 on November 20)	O.P.+ 2,915 mm (26 mm decrease since 7:00 on November 20)	O.P.+ 2,715 mm (11 mm increase since 7:00 on November 20)	O.P.+ 2,726 mm (6 mm increase since 7:00 on November 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,293 mm (Increase from initial level:5,510 mm, 4 mm increase since 7:00 on November 20) O.P.+ 1,445 mm (Increase from initial level:2,171 mm, 78 mm increase since 7:00 on November 20) O.P.+ 4,231 mm (Water level from floor:435 mm, 9 mm increase since 7:00 on November 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 15:07 on November 13)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:25 on November 20   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:30 AM on November 20, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning. At 12:28 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved 13:25 PM.				

※ For quick publication of the data of water level, values are provided as reference values.