

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 25)**

Water Level of the accumulated water (at 7:00 on November 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,674 mm (26 mm decrease since 7:00 on November 24)	O.P.+ 2,528 mm (8 mm increase since 7:00 on November 24)	—
	Water level of Turbine Building	O.P.+ 2,809 mm (9 mm increase since 7:00 on November 24)	O.P.+ 2,687 mm (36 mm decrease since 7:00 on November 24)	O.P.+ 2,752 mm (7 mm increase since 7:00 on November 24)	O.P.+ 2,706 mm (8 mm increase since 7:00 on November 24)
	Water level of Reactor Building	O.P.+ 4,350 mm (15 mm decrease since 7:00 on November 24)	O.P.+ 2,797 mm (26 mm decrease since 7:00 on November 24)	O.P.+ 2,753 mm (12 mm increase since 7:00 on November 24)	O.P.+ 2,753 mm (8 mm increase since 7:00 on November 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,306 mm (Increase from initial level:5,523 mm, 8 mm increase since 7:00 on November 24) O.P.+ 1,093 mm (Increase from initial level:1,819 mm, 80 mm decrease since 7:00 on November 24) O.P.+ 4,265 mm (Water level from floor:469 mm, 9 mm increase since 7:00 on November 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 15:07 on November 13)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:25 on November 20   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.