

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 28)**

Water Level of the accumulated water (at 7:00 on November 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,646 mm (20 mm decrease since 7:00 on November 27)	O.P.+ 2,507 mm (24 mm decrease since 7:00 on November 27)	—
	Water level of Turbine Building	O.P.+ 2,859 mm (23 mm increase since 7:00 on November 27)	O.P.+ 2,639 mm (22 mm decrease since 7:00 on November 27)	O.P.+ 2,658 mm (56 mm decrease since 7:00 on November 27)	O.P.+ 2,700 mm (15 mm decrease since 7:00 on November 27)
	Water level of Reactor Building	O.P.+ 4,478 mm (8 mm increase since 7:00 on November 27)	O.P.+ 2,753 mm (22 mm decrease since 7:00 on November 27)	O.P.+ 2,661 mm (60 mm decrease since 7:00 on November 27)	O.P.+ 2,752 mm (12 mm decrease since 7:00 on November 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,066 mm (Increase from initial level:5,283 mm, 20 mm decrease since 7:00 on November 27) O.P.+ 1,196 mm (Increase from initial level:1,922 mm, 228 mm increase since 7:00 on November 27) O.P.+ 4,296 mm (Water level from floor:500 mm, 11 mm increase since 7:00 on November 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:23 on November 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building Temporary Tank	Transfer Completed	(From 10:00 on November 27 to 15:00 on November 27)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:45 on November 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:29 on November 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:21 AM on November 27, we temporarily stopped the Second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:04 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 12:29 PM.				

For quick publication of the data of water level, values are provided as reference values.