

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 1)**

Water Level of the accumulated water (at 7:00 on December 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,619 mm (26 mm decrease since 7:00 on November 30)	O.P.+ 2,426 mm (27 mm decrease since 7:00 on November 30)	—
	Water level of Turbine Building	O.P.+ 2,657 mm (249 mm decrease since 7:00 on November 30)	O.P.+ 2,567 mm (42 mm decrease since 7:00 on November 30)	O.P.+ 2,530 mm (40 mm decrease since 7:00 on November 30)	O.P.+ 2,633 mm (25 mm decrease since 7:00 on November 30)
	Water level of Reactor Building	O.P.+ 4,424 mm (44 mm decrease since 7:00 on November 30)	O.P.+ 2,691 mm (31 mm decrease since 7:00 on November 30)	O.P.+ 2,527 mm (44 mm decrease since 7:00 on November 30)	O.P.+ 2,692 mm (22 mm decrease since 7:00 on November 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,014 mm (Increase from initial level:5,231 mm, 25 mm decrease since 7:00 on November 30) O.P.+ 1,522 mm (Increase from initial level:2,248 mm, 109 mm increase since 7:00 on November 30) O.P.+ 4,326 mm (Water level from floor:530 mm, 9 mm increase since 7:00 on November 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 9:50 on November 30 to 17:40 on November 30)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:23 on November 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:45 on November 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:29 on November 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.