

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 2)**

Water Level of the accumulated water (at 7:00 on December 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,651 mm (32 mm increase since 7:00 on December 1)	O.P.+ 2,401 mm (25 mm decrease since 7:00 on December 1)	—
	Water level of Turbine Building	O.P.+ 2,681 mm (24 mm increase since 7:00 on December 1)	O.P.+ 2,567 mm (No change since 7:00 on December 1)	O.P.+ 2,498 mm (32 mm decrease since 7:00 on December 1)	O.P.+ 2,608 mm (25 mm decrease since 7:00 on December 1)
	Water level of Reactor Building	O.P.+ 4,410 mm (14 mm decrease since 7:00 on December 1)	O.P.+ 2,688 mm (3 mm decrease since 7:00 on December 1)	O.P.+ 2,487 mm (40 mm decrease since 7:00 on December 1)	O.P.+ 2,668 mm (24 mm decrease since 7:00 on December 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,000 mm (Increase from initial level:5,217 mm, 14 mm decrease since 7:00 on December 1) O.P.+ 1,645 mm (Increase from initial level:2,371 mm, 123 mm increase since 7:00 on December 1) O.P.+ 4,334 mm (Water level from floor:538 mm, 8 mm increase since 7:00 on December 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 9:50 on November 30 to 17:40 on November 30)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:23 on November 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on December 1 to 15:00 on December 1)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:45 on November 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:29 on November 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.