

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 3)**

Water Level of the accumulated water (at 7:00 on December 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,666 mm (15 mm increase since 7:00 on December 2)	O.P.+ 2,372 mm (29 mm decrease since 7:00 on December 2)	—
	Water level of Turbine Building	O.P.+ 2,705 mm (24 mm increase since 7:00 on December 2)	O.P.+ 2,557 mm (10 mm decrease since 7:00 on December 2)	O.P.+ 2,459 mm (39 mm decrease since 7:00 on December 2)	O.P.+ 2,582 mm (26 mm decrease since 7:00 on December 2)
	Water level of Reactor Building	O.P.+ 4,379 mm (31 mm decrease since 7:00 on December 2)	O.P.+ 2,664 mm (24 mm decrease since 7:00 on December 2)	O.P.+ 2,438 mm (49 mm decrease since 7:00 on December 2)	O.P.+ 2,645 mm (23 mm decrease since 7:00 on December 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,964 mm (Increase from initial level:5,181 mm, 36 mm decrease since 7:00 on December 2) O.P.+ 1,772 mm (Increase from initial level:2,498 mm, 127 mm increase since 7:00 on December 2) O.P.+ 4,342 mm (Water level from floor:546 mm, 8 mm increase since 7:00 on December 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:23 on November 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:45 on November 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:29 on November 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.