

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 4)**

Water Level of the accumulated water (at 7:00 on December 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,677 mm (11 mm increase since 7:00 on December 3)	O.P.+ 2,341 mm (31 mm decrease since 7:00 on December 3)	—
	Water level of Turbine Building	O.P.+ 2,728 mm (23 mm increase since 7:00 on December 3)	O.P.+ 2,550 mm (7 mm decrease since 7:00 on December 3)	O.P.+ 2,423 mm (36 mm decrease since 7:00 on December 3)	O.P.+ 2,555 mm (27 mm decrease since 7:00 on December 3)
	Water level of Reactor Building	O.P.+ 4,351 mm (28 mm decrease since 7:00 on December 3)	O.P.+ 2,653 mm (11 mm decrease since 7:00 on December 3)	O.P.+ 2,426 mm (12 mm decrease since 7:00 on December 3)	O.P.+ 2,620 mm (25 mm decrease since 7:00 on December 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,151 mm (Increase from initial level:5,368 mm, 187 mm increase since 7:00 on December 3) O.P.+ 1,902 mm (Increase from initial level:2,628 mm, 130 mm increase since 7:00 on December 3) O.P.+ 4,349 mm (Water level from floor:553 mm, 7 mm increase since 7:00 on December 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:23 on November 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on December 3 to 15:00 on December 3)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:50 on December 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:08 on December 4 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* From 08:08 on December 4, we temporary stopped the Second Cesium Adsorption Apparatus (SARRY) for cleaning the filter.				

※ For quick publication of the data of water level, values are provided as reference values.