

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 5)**

Water Level of the accumulated water (at 7:00 on December 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,695 mm (18 mm increase since 7:00 on December 4)	O.P.+ 2,311 mm (30 mm decrease since 7:00 on December 4)	—
	Water level of Turbine Building	O.P.+ 2,750 mm (22 mm increase since 7:00 on December 4)	O.P.+ 2,553 mm (3 mm increase since 7:00 on December 4)	O.P.+ 2,388 mm (35 mm decrease since 7:00 on December 4)	O.P.+ 2,529 mm (26 mm decrease since 7:00 on December 4)
	Water level of Reactor Building	O.P.+ 4,330 mm (21 mm decrease since 7:00 on December 4)	O.P.+ 2,657 mm (4 mm increase since 7:00 on December 4)	O.P.+ 2,388 mm (38 mm decrease since 7:00 on December 4)	O.P.+ 2,597 mm (23 mm decrease since 7:00 on December 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,435 mm (Increase from initial level:5,652 mm, 284 mm increase since 7:00 on December 4) O.P.+ 2,095 mm (Increase from initial level:2,821 mm, 193 mm increase since 7:00 on December 4) O.P.+ 4,356 mm (Water level from floor:560 mm, 7 mm increase since 7:00 on December 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:23 on November 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:50 on December 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:03 on December 5   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:08 AM on December 4, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 3:24 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 4:03 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.