

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 8)**

Water Level of the accumulated water (at 7:00 on December 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,674 mm (15 mm decrease since 7:00 on December 7)	O.P.+ 2,324 mm (13 mm increase since 7:00 on December 7)	—
	Water level of Turbine Building	O.P.+ 2,812 mm (20 mm increase since 7:00 on December 7)	O.P.+ 2,514 mm (34 mm decrease since 7:00 on December 7)	O.P.+ 2,515 mm (30 mm increase since 7:00 on December 7)	O.P.+ 2,491 mm (3 mm decrease since 7:00 on December 7)
	Water level of Reactor Building	O.P.+ 4,254 mm (33 mm decrease since 7:00 on December 7)	O.P.+ 2,616 mm (32 mm decrease since 7:00 on December 7)	O.P.+ 2,516 mm (35 mm increase since 7:00 on December 7)	O.P.+ 2,560 mm (3 mm decrease since 7:00 on December 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,576 mm (Increase from initial level:5,793 mm, 15 mm increase since 7:00 on December 7) O.P.+ 1,989 mm (Increase from initial level:2,715 mm, 31 mm decrease since 7:00 on December 7) O.P.+ 4,213 mm (Water level from floor:417 mm, 6 mm increase since 7:00 on December 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:47 on December 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:50 on December 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:03 on December 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.