

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 9)**

Water Level of the accumulated water (at 7:00 on December 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,673 mm (1 mm decrease since 7:00 on December 8)	O.P.+ 2,335 mm (11 mm increase since 7:00 on December 8)	—
	Water level of Turbine Building	O.P.+ 2,827 mm (15 mm increase since 7:00 on December 8)	O.P.+ 2,481 mm (33 mm decrease since 7:00 on December 8)	O.P.+ 2,531 mm (16 mm increase since 7:00 on December 8)	O.P.+ 2,500 mm (9 mm increase since 7:00 on December 8)
	Water level of Reactor Building	O.P.+ 4,222 mm (32 mm decrease since 7:00 on December 8)	O.P.+ 2,588 mm (28 mm decrease since 7:00 on December 8)	O.P.+ 2,537 mm (21 mm increase since 7:00 on December 8)	O.P.+ 2,565 mm (5 mm increase since 7:00 on December 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,324 mm (Increase from initial level:5,541 mm, 252 mm decrease since 7:00 on December 8) O.P.+ 1,970 mm (Increase from initial level:2,696 mm, 19 mm decrease since 7:00 on December 8) O.P.+ 4,221 mm (Water level from floor:425 mm, 8 mm increase since 7:00 on December 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:47 on December 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on December 8 to 15:00 on December 8)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:25 on December 8 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:03 on December 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.