

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 10)**

Water Level of the accumulated water (at 7:00 on December 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,675 mm (2 mm increase since 7:00 on December 9)	O.P.+ 2,345 mm (10 mm increase since 7:00 on December 9)	—
	Water level of Turbine Building	O.P.+ 2,847 mm (20 mm increase since 7:00 on December 9)	O.P.+ 2,472 mm (9 mm decrease since 7:00 on December 9)	O.P.+ 2,544 mm (13 mm increase since 7:00 on December 9)	O.P.+ 2,509 mm (9 mm increase since 7:00 on December 9)
	Water level of Reactor Building	O.P.+ 4,186 mm (36 mm decrease since 7:00 on December 9)	O.P.+ 2,576 mm (12 mm decrease since 7:00 on December 9)	O.P.+ 2,549 mm (12 mm increase since 7:00 on December 9)	O.P.+ 2,574 mm (9 mm increase since 7:00 on December 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,047 mm (Increase from initial level:5,264 mm, 277 mm decrease since 7:00 on December 9) O.P.+ 1,967 mm (Increase from initial level:2,693 mm, 3 mm decrease since 7:00 on December 9) O.P.+ 4,227 mm (Water level from floor:431 mm, 6 mm increase since 7:00 on December 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:47 on December 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:25 on December 8 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:03 on December 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.