

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 11)**

Water Level of the accumulated water (at 7:00 on December 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,680 mm (5 mm increase since 7:00 on December 10)	O.P.+ 2,356 mm (11 mm increase since 7:00 on December 10)	—
	Water level of Turbine Building	O.P.+ 2,862 mm (15 mm increase since 7:00 on December 10)	O.P.+ 2,451 mm (21 mm decrease since 7:00 on December 10)	O.P.+ 2,558 mm (14 mm increase since 7:00 on December 10)	O.P.+ 2,520 mm (11 mm increase since 7:00 on December 10)
	Water level of Reactor Building	O.P.+ 4,155 mm (31 mm decrease since 7:00 on December 10)	O.P.+ 2,562 mm (14 mm decrease since 7:00 on December 10)	O.P.+ 2,563 mm (14 mm increase since 7:00 on December 10)	O.P.+ 2,583 mm (9 mm increase since 7:00 on December 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,775 mm (Increase from initial level:4,992 mm, 272 mm decrease since 7:00 on December 10) O.P.+ 1,980 mm (Increase from initial level:2,706 mm, 13 mm increase since 7:00 on December 10) O.P.+ 4,234 mm (Water level from floor:438 mm, 7 mm increase since 7:00 on December 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:47 on December 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on December 10 to 15:00 on December 10)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:25 on December 8 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:18 on December 11 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*At 8:18 AM on Dec 11, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) to conduct a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.