

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 15)**

Water Level of the accumulated water (at 7:00 on December 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,659 mm (3 mm decrease since 7:00 on December 14)	O.P.+ 2,354 mm (7 mm decrease since 7:00 on December 14)	—
	Water level of Turbine Building	O.P.+ 2,919 mm (13 mm increase since 7:00 on December 14)	O.P.+ 2,410 mm (9 mm decrease since 7:00 on December 14)	O.P.+ 2,534 mm (16 mm decrease since 7:00 on December 14)	O.P.+ 2,532 mm (4 mm decrease since 7:00 on December 14)
	Water level of Reactor Building	O.P.+ 4,083 mm (13 mm decrease since 7:00 on December 14)	O.P.+ 2,500 mm (11 mm decrease since 7:00 on December 14)	O.P.+ 2,539 mm (17 mm decrease since 7:00 on December 14)	O.P.+ 2,596 mm (3 mm decrease since 7:00 on December 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,740 mm (Increase from initial level:4,957 mm, 317 mm increase since 7:00 on December 14) O.P.+ 1,479 mm (Increase from initial level:2,205 mm, 558 mm decrease since 7:00 on December 14) O.P.+ 4,260 mm (Water level from floor:464 mm, 7 mm increase since 7:00 on December 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:47 on December 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:06 on December 12 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:39 on December 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.