

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 17)**

Water Level of the accumulated water (at 7:00 on December 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,070 mm (588 mm decrease since 7:00 on December 16)	O.P.+ 2,302 mm (6 mm decrease since 7:00 on December 16)	—
	Water level of Turbine Building	O.P.+ 2,940 mm (13 mm increase since 7:00 on December 16)	O.P.+ 2,508 mm (76 mm increase since 7:00 on December 16)	O.P.+ 2,515 mm (2 mm decrease since 7:00 on December 16)	O.P.+ 2,513 mm (7 mm decrease since 7:00 on December 16)
	Water level of Reactor Building	O.P.+ 4,094 mm (28 mm increase since 7:00 on December 16)	O.P.+ 2,604 mm (86 mm increase since 7:00 on December 16)	O.P.+ 2,517 mm (1 mm decrease since 7:00 on December 16)	O.P.+ 2,579 mm (5 mm decrease since 7:00 on December 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,789 mm (Increase from initial level:5,006 mm, 2 mm increase since 7:00 on December 16) O.P.+ 1,526 mm (Increase from initial level:2,252 mm, 28 mm increase since 7:00 on December 16) O.P.+ 4,274 mm (Water level from floor:478 mm, 8 mm increase since 7:00 on December 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:47 on December 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:34 on December 14)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:31 on December 15 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:39 on December 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.