

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 18)**

Water Level of the accumulated water (at 7:00 on December 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,092 mm (22 mm increase since 7:00 on December 17)	O.P.+ 2,305 mm (3 mm increase since 7:00 on December 17)	—
	Water level of Turbine Building	O.P.+ 2,952 mm (12 mm increase since 7:00 on December 17)	O.P.+ 2,501 mm (7 mm decrease since 7:00 on December 17)	O.P.+ 2,507 mm (8 mm decrease since 7:00 on December 17)	O.P.+ 2,508 mm (5 mm decrease since 7:00 on December 17)
	Water level of Reactor Building	O.P.+ 4,111 mm (17 mm increase since 7:00 on December 17)	O.P.+ 2,599 mm (5 mm decrease since 7:00 on December 17)	O.P.+ 2,507 mm (10 mm decrease since 7:00 on December 17)	O.P.+ 2,576 mm (3 mm decrease since 7:00 on December 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,800 mm (Increase from initial level:5,017 mm, 11 mm increase since 7:00 on December 17) O.P.+ 1,543 mm (Increase from initial level:2,269 mm, 17 mm increase since 7:00 on December 17) O.P.+ 4,279 mm (Water level from floor:483 mm, 5 mm increase since 7:00 on December 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:47 on December 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:34 on December 14)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on December 17 to 15:00 on December 17)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:31 on December 15 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:39 on December 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.