

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 19)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on December 19)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,284 mm (192 mm increase since 7:00 on December 18)	O.P.+ 2,291 mm (14 mm decrease since 7:00 on December 18)	—
	Water level of Turbine Building	O.P.+ 2,962 mm (10 mm increase since 7:00 on December 18)	O.P.+ 2,490 mm (11 mm decrease since 7:00 on December 18)	O.P.+ 2,499 mm (8 mm decrease since 7:00 on December 18)	O.P.+ 2,501 mm (7 mm decrease since 7:00 on December 18)
	Water level of Reactor Building	O.P.+ 4,107 mm (4 mm decrease since 7:00 on December 18)	O.P.+ 2,574 mm (25 mm decrease since 7:00 on December 18)	O.P.+ 2,498 mm (9 mm decrease since 7:00 on December 18)	O.P.+ 2,569 mm (7 mm decrease since 7:00 on December 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,810 mm (Increase from initial level:5,027 mm, 10 mm increase since 7:00 on December 18) O.P.+ 1,563 mm (Increase from initial level:2,289 mm, 20 mm increase since 7:00 on December 18) O.P.+ 4,286 mm (Water level from floor:490 mm, 7 mm increase since 7:00 on December 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:47 on December 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:34 on December 14)	—
		Unit 5 and 6 —			
Operation condition of water treatment facility	Cesium Adsorption Apparatus: Since 11:31 on December 15 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:39 on December 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes					

※ For quick publication of the data of water level, values are provided as reference values.