

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 22)**

Water Level of the accumulated water (at 7:00 on December 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,266 mm (5 mm decrease since 7:00 on December 21)	O.P.+ 2,312 mm (7 mm increase since 7:00 on December 21)	—
	Water level of Turbine Building	O.P.+ 2,540 mm (441 mm decrease since 7:00 on December 21)	O.P.+ 2,516 mm (8 mm increase since 7:00 on December 21)	O.P.+ 2,539 mm (6 mm increase since 7:00 on December 21)	O.P.+ 2,509 mm (8 mm increase since 7:00 on December 21)
	Water level of Reactor Building	O.P.+ 4,101 mm (11 mm decrease since 7:00 on December 21)	O.P.+ 2,612 mm (2 mm increase since 7:00 on December 21)	O.P.+ 2,544 mm (7 mm increase since 7:00 on December 21)	O.P.+ 2,571 mm (7 mm increase since 7:00 on December 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,658 mm (Increase from initial level:4,875 mm, 56 mm decrease since 7:00 on December 21) O.P.+ 1,460 mm (Increase from initial level:2,186 mm, 2 mm increase since 7:00 on December 21) O.P.+ 4,305 mm (Water level from floor:509 mm, 6 mm increase since 7:00 on December 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (Since 17:41 on December 21)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:47 on December 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:34 on December 14)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:31 on December 15 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:39 on December 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.