

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 24)**

Water Level of the accumulated water (at 7:00 on December 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,263 mm (2 mm increase since 7:00 on December 23)	O.P.+ 2,274 mm (22 mm decrease since 7:00 on December 23)	—
	Water level of Turbine Building	O.P.+ 2,446 mm (11 mm increase since 7:00 on December 23)	O.P.+ 2,562 mm (13 mm increase since 7:00 on December 23)	O.P.+ 2,459 mm (39 mm decrease since 7:00 on December 23)	O.P.+ 2,496 mm (11 mm decrease since 7:00 on December 23)
	Water level of Reactor Building	O.P.+ 4,084 mm (11 mm decrease since 7:00 on December 23)	O.P.+ 2,640 mm (9 mm increase since 7:00 on December 23)	O.P.+ 2,460 mm (41 mm decrease since 7:00 on December 23)	O.P.+ 2,561 mm (10 mm decrease since 7:00 on December 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,555 mm (Increase from initial level:4,772 mm, 105 mm decrease since 7:00 on December 23) O.P.+ 2,083 mm (Increase from initial level:2,809 mm, 337 mm increase since 7:00 on December 23) O.P.+ 4,316 mm (Water level from floor:520 mm, 5 mm increase since 7:00 on December 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 17:41 on December 21 to 10:07 on December 22)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:34 on December 14)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:04 on December 22 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:39 on December 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.