

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 25)**

Water Level of the accumulated water (at 7:00 on December 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,380 mm (883 mm decrease since 7:00 on December 24)	O.P.+ 2,262 mm (12 mm decrease since 7:00 on December 24)	—
	Water level of Turbine Building	O.P.+ 2,459 mm (13 mm increase since 7:00 on December 24)	O.P.+ 2,597 mm (35 mm increase since 7:00 on December 24)	O.P.+ 2,445 mm (14 mm decrease since 7:00 on December 24)	O.P.+ 2,484 mm (12 mm decrease since 7:00 on December 24)
	Water level of Reactor Building	O.P.+ 4,083 mm (1 mm decrease since 7:00 on December 24)	O.P.+ 2,681 mm (41 mm increase since 7:00 on December 24)	O.P.+ 2,441 mm (19 mm decrease since 7:00 on December 24)	O.P.+ 2,550 mm (11 mm decrease since 7:00 on December 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,456 mm (Increase from initial level:4,673 mm, 99 mm decrease since 7:00 on December 24) O.P.+ 2,416 mm (Increase from initial level:3,142 mm, 333 mm increase since 7:00 on December 24) O.P.+ 4,320 mm (Water level from floor:524 mm, 4 mm increase since 7:00 on December 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:34 on December 14)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed	(From 10:00 on December 24 to 15:00 on December 24)
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:04 on December 22 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:39 on December 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.