

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 26)**

Water Level of the accumulated water (at 7:00 on December 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,451 mm (71 mm increase since 7:00 on December 25)	O.P.+ 2,247 mm (15 mm decrease since 7:00 on December 25)	—
	Water level of Turbine Building	O.P.+ 2,467 mm (8 mm increase since 7:00 on December 25)	O.P.+ 2,609 mm (12 mm increase since 7:00 on December 25)	O.P.+ 2,427 mm (18 mm decrease since 7:00 on December 25)	O.P.+ 2,471 mm (13 mm decrease since 7:00 on December 25)
	Water level of Reactor Building	O.P.+ 4,067 mm (16 mm decrease since 7:00 on December 25)	O.P.+ 2,689 mm (8 mm increase since 7:00 on December 25)	O.P.+ 2,421 mm (20 mm decrease since 7:00 on December 25)	O.P.+ 2,539 mm (11 mm decrease since 7:00 on December 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,361 mm (Increase from initial level:4,578 mm, 95 mm decrease since 7:00 on December 25) O.P.+ 2,743 mm (Increase from initial level:3,469 mm, 327 mm increase since 7:00 on December 25) O.P.+ 4,325 mm (Water level from floor:529 mm, 5 mm increase since 7:00 on December 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:34 on December 14)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on December 25 to 15:00 on December 25)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:04 on December 22 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:39 on December 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.