

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 5)**

|   |  |   |   |  |  |
|---|--|---|---|--|--|
| Water Level of the accumulated water (at 7:00 on January 5) |  | Unit 1  | Unit 2  | Unit 3   | Unit 4   |
|   | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)   | O.P.+ 2,023 mm<br>(26 mm increase since 7:00 on January 4)  | O.P.+ 2,406 mm<br>(16 mm increase since 7:00 on January 4) | —  |
|   | Water level of Turbine Building  | O.P.+ 2,547 mm<br>(6 mm increase since 7:00 on January 4)   | O.P.+ 2,561 mm<br>(10 mm decrease since 7:00 on January 4)  | O.P.+ 2,640 mm<br>(17 mm increase since 7:00 on January 4) | O.P.+ 2,583 mm<br>(14 mm increase since 7:00 on January 4) |
|   | Water level of Reactor Building  | O.P.+ 4,032 mm<br>(18 mm decrease since 7:00 on January 4)  | O.P.+ 2,657 mm<br>(9 mm decrease since 7:00 on January 4)   | O.P.+ 2,650 mm<br>(14 mm increase since 7:00 on January 4) | O.P.+ 2,627 mm<br>(13 mm increase since 7:00 on January 4) |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building   | O.P.+ 3,389 mm (Increase from initial level:4,606 mm, 3 mm increase since 7:00 on January 4)<br>O.P.+ 2,252 mm (Increase from initial level:2,978 mm, 7 mm decrease since 7:00 on January 4)<br>O.P.+ 4,367 mm (Water level from floor:571 mm, 5 mm increase since 7:00 on January 4) |  |  |
| Situation of transfer of the accumulated water              |  | Unit 1  | Unit 2  | Unit 3   | Unit 4   |
|   |  | —   | Basement of Unit 2 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred<br>(Since 9:58 on December 22)  | —  | —  |
|   |  | Unit 5 and 6  |   |  |  |
|   |  | —   |   |  |  |
| Operation condition of water treatment facility             |  | Cesium Adsorption Apparatus: Since 9:14 on December 26   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 13:43 on December 26   In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |   |  |  |
| Notes   |  |   |   |  |  |

※ For quick publication of the data of water level, values are provided as reference values.