

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 6)**

|  |  |   |   |  |  |
|--|--|---|---|--|--|
| Water Level of the accumulated water<br>(at 7:00 on January 6) |  | Unit 1  | Unit 2  | Unit 3   | Unit 4   |
|  | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)   | O.P.+ 2,045 mm<br>(22 mm increase since 7:00 on January 5)  | O.P.+ 2,420 mm<br>(14 mm increase since 7:00 on January 5) | —  |
|  | Water level of Turbine Building  | O.P.+ 2,551 mm<br>(4 mm increase since 7:00 on January 5)   | O.P.+ 2,547 mm<br>(14 mm decrease since 7:00 on January 5)  | O.P.+ 2,655 mm<br>(15 mm increase since 7:00 on January 5) | O.P.+ 2,597 mm<br>(14 mm increase since 7:00 on January 5) |
|  | Water level of Reactor Building  | O.P.+ 4,021 mm<br>(11 mm decrease since 7:00 on January 5)  | O.P.+ 2,649 mm<br>(8 mm decrease since 7:00 on January 5)   | O.P.+ 2,669 mm<br>(19 mm increase since 7:00 on January 5) | O.P.+ 2,642 mm<br>(15 mm increase since 7:00 on January 5) |
|  | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building   | O.P.+ 3,398 mm (Increase from initial level:4,615 mm, 9 mm increase since 7:00 on January 5)<br>O.P.+ 2,251 mm (Increase from initial level:2,977 mm, 1 mm decrease since 7:00 on January 5)<br>O.P.+ 4,371 mm (Water level from floor:575 mm, 4 mm increase since 7:00 on January 5) |  |  |
| Situation of transfer of the accumulated water                 |  | Unit 1  | Unit 2  | Unit 3   | Unit 4   |
|  |  | —   | Basement of Unit 2 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred<br>(Since 9:58 on December 22)  | —  | —  |
|  |  | Unit 5 and 6  |   |  |  |
|  |  | —   |   |  |  |
| Operation condition of water treatment facility                |  | Cesium Adsorption Apparatus: Since 9:14 on December 26   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 13:43 on December 26   In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |   |  |  |
| Notes  |  |   |   |  |  |

※ For quick publication of the data of water level, values are provided as reference values.