

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 7)

Water Level of the accumulated water (at 7:00 on January 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,064 mm (19 mm increase since 7:00 on January 6)	O.P.+ 2,434 mm (14 mm increase since 7:00 on January 6)	—
	Water level of Turbine Building	O.P.+ 2,341 mm (210 mm decrease since 7:00 on January 6)	O.P.+ 2,563 mm (16 mm increase since 7:00 on January 6)	O.P.+ 2,672 mm (17 mm increase since 7:00 on January 6)	O.P.+ 2,614 mm (17 mm increase since 7:00 on January 6)
	Water level of Reactor Building	O.P.+ 4,003 mm (18 mm decrease since 7:00 on January 6)	O.P.+ 2,664 mm (15 mm increase since 7:00 on January 6)	O.P.+ 2,689 mm (20 mm increase since 7:00 on January 6)	O.P.+ 2,657 mm (15 mm increase since 7:00 on January 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,233 mm (Increase from initial level:4,450 mm, 165 mm decrease since 7:00 on January 6) O.P.+ 2,331 mm (Increase from initial level:3,057 mm, 80 mm increase since 7:00 on January 6) O.P.+ 4,375 mm (Water level from floor:579 mm, 4 mm increase since 7:00 on January 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 9:46 on January 6 to 16:04 on January 6)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on January 6 to 15:00 on January 6)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:47 on January 6 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:24 on January 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	※1 At 11:47 AM on January 6, Since the preparation of Cesium and Tritium treatment has been completed, started the CesiumAdsorption Apparatus and the steady flow rate was achieved. ※2 At 9:18 AM on January 6, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) and cleaned a filter. At 13:11 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 13:24 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.