

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 8)**

Water Level of the accumulated water (at 7:00 on January 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,080 mm (16 mm increase since 7:00 on January 7)	O.P.+ 2,451 mm (17 mm increase since 7:00 on January 7)	—
	Water level of Turbine Building	O.P.+ 2,347 mm (6 mm increase since 7:00 on January 7)	O.P.+ 2,574 mm (11 mm increase since 7:00 on January 7)	O.P.+ 2,687 mm (15 mm increase since 7:00 on January 7)	O.P.+ 2,628 mm (14 mm increase since 7:00 on January 7)
	Water level of Reactor Building	O.P.+ 3,990 mm (13 mm decrease since 7:00 on January 7)	O.P.+ 2,669 mm (5 mm increase since 7:00 on January 7)	O.P.+ 2,707 mm (18 mm increase since 7:00 on January 7)	O.P.+ 2,620 mm (37 mm decrease since 7:00 on January 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,019 mm (Increase from initial level:4,236 mm, 214 mm decrease since 7:00 on January 7) O.P.+ 2,188 mm (Increase from initial level:2,914 mm, 143 mm decrease since 7:00 on January 7) O.P.+ 4,378 mm (Water level from floor:582 mm, 3 mm increase since 7:00 on January 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on January 7 to 15:00 on January 7)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:47 on January 6 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:24 on January 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.