

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 9)**

Water Level of the accumulated water (at 7:00 on January 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,094 mm (14 mm increase since 7:00 on January 8)	O.P.+ 2,463 mm (12 mm increase since 7:00 on January 8)	—
	Water level of Turbine Building	O.P.+ 2,350 mm (3 mm increase since 7:00 on January 8)	O.P.+ 2,573 mm (1 mm decrease since 7:00 on January 8)	O.P.+ 2,702 mm (15 mm increase since 7:00 on January 8)	O.P.+ 2,643 mm (15 mm increase since 7:00 on January 8)
	Water level of Reactor Building	O.P.+ 3,976 mm (14 mm decrease since 7:00 on January 8)	O.P.+ 2,668 mm (1 mm decrease since 7:00 on January 8)	O.P.+ 2,718 mm (11 mm increase since 7:00 on January 8)	O.P.+ 2,632 mm (12 mm increase since 7:00 on January 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,816 mm (Increase from initial level:4,033 mm, 203 mm decrease since 7:00 on January 8) O.P.+ 2,150 mm (Increase from initial level:2,876 mm, 38 mm decrease since 7:00 on January 8) O.P.+ 4,381 mm (Water level from floor:585 mm, 3 mm increase since 7:00 on January 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:47 on January 6 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:24 on January 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.