

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 13)**

Water Level of the accumulated water (at 7:00 on January 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,126 mm (6 mm increase since 7:00 on January 12)	O.P.+ 2,518 mm (11 mm increase since 7:00 on January 12)	—
	Water level of Turbine Building	O.P.+ 2,360 mm (2 mm increase since 7:00 on January 12)	O.P.+ 2,528 mm (11 mm decrease since 7:00 on January 12)	O.P.+ 2,763 mm (14 mm increase since 7:00 on January 12)	O.P.+ 2,701 mm (15 mm increase since 7:00 on January 12)
	Water level of Reactor Building	O.P.+ 3,901 mm (24 mm decrease since 7:00 on January 12)	O.P.+ 2,622 mm (17 mm decrease since 7:00 on January 12)	O.P.+ 2,792 mm (17 mm increase since 7:00 on January 12)	O.P.+ 2,688 mm (14 mm increase since 7:00 on January 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,627 mm (Increase from initial level:3,844 mm, 4 mm increase since 7:00 on January 12) O.P.+ 2,064 mm (Increase from initial level:2,790 mm, 14 mm decrease since 7:00 on January 12) O.P.+ 4,393 mm (Water level from floor:597 mm, 3 mm increase since 7:00 on January 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:19 on January 10   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:24 on January 6   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.