

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 15)**

Water Level of the accumulated water (at 7:00 on January 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,136 mm (2 mm increase since 7:00 on January 14)	O.P.+ 2,546 mm (14 mm increase since 7:00 on January 14)	—
	Water level of Turbine Building	O.P.+ 2,361 mm (2 mm increase since 7:00 on January 14)	O.P.+ 2,505 mm (23 mm decrease since 7:00 on January 14)	O.P.+ 2,794 mm (16 mm increase since 7:00 on January 14)	O.P.+ 2,729 mm (16 mm increase since 7:00 on January 14)
	Water level of Reactor Building	O.P.+ 3,866 mm (11 mm decrease since 7:00 on January 14)	O.P.+ 2,614 mm (8 mm decrease since 7:00 on January 14)	O.P.+ 2,817 mm (14 mm increase since 7:00 on January 14)	O.P.+ 2,718 mm (15 mm increase since 7:00 on January 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,694 mm (Increase from initial level:3,911 mm, 4 mm increase since 7:00 on January 14) O.P.+ 2,141 mm (Increase from initial level:2,867 mm, 64 mm increase since 7:00 on January 14) O.P.+ 4,227 mm (Water level from floor:431 mm, 4 mm increase since 7:00 on January 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	—	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:19 on January 10 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:35 on January 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 9:24 AM on July 14, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 13:16 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 13:35 PM.				

For quick publication of the data of water level, values are provided as reference values.