

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 16)**

Water Level of the accumulated water (at 7:00 on January 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,142 mm (6 mm increase since 7:00 on January 15)	O.P.+ 2,564 mm (18 mm increase since 7:00 on January 15)	—
	Water level of Turbine Building	O.P.+ 2,361 mm (No change since 7:00 on January 15)	O.P.+ 2,508 mm (3 mm increase since 7:00 on January 15)	O.P.+ 2,814 mm (20 mm increase since 7:00 on January 15)	O.P.+ 2,744 mm (15 mm increase since 7:00 on January 15)
	Water level of Reactor Building	O.P.+ 3,879 mm (13 mm increase since 7:00 on January 15)	O.P.+ 2,623 mm (9 mm increase since 7:00 on January 15)	O.P.+ 2,846 mm (29 mm increase since 7:00 on January 15)	O.P.+ 2,732 mm (14 mm increase since 7:00 on January 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,699 mm (Increase from initial level:3,916 mm, 5 mm increase since 7:00 on January 15) O.P.+ 2,077 mm (Increase from initial level:2,803 mm, 64 mm decrease since 7:00 on January 15) O.P.+ 4,230 mm (Water level from floor:434 mm, 3 mm increase since 7:00 on January 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on January 15 to 15:00 on January 15)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:19 on January 10 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:35 on January 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.