

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 19)**

Water Level of the accumulated water (at 7:00 on January 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,141 mm (2 mm decrease since 7:00 on January 18)	O.P.+ 2,567 mm (24 mm decrease since 7:00 on January 18)	—
	Water level of Turbine Building	O.P.+ 2,366 mm (1 mm increase since 7:00 on January 18)	O.P.+ 2,533 mm (5 mm increase since 7:00 on January 18)	O.P.+ 2,794 mm (49 mm decrease since 7:00 on January 18)	O.P.+ 2,777 mm (3 mm increase since 7:00 on January 18)
	Water level of Reactor Building	O.P.+ 3,881 mm (12 mm decrease since 7:00 on January 18)	O.P.+ 2,622 mm (1 mm increase since 7:00 on January 18)	O.P.+ 2,828 mm (47 mm decrease since 7:00 on January 18)	O.P.+ 2,771 mm (11 mm increase since 7:00 on January 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,918 mm (Increase from initial level:4,135 mm, 209 mm increase since 7:00 on January 18) O.P.+ 1,917 mm (Increase from initial level:2,643 mm, 50 mm decrease since 7:00 on January 18) O.P.+ 4,238 mm (Water level from floor:442 mm, 3 mm increase since 7:00 on January 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:21 on January 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:19 on January 10 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:35 on January 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.