

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 20)**

Water Level of the accumulated water (at 7:00 on January 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,141 mm (No change since 7:00 on January 19)	O.P.+ 2,545 mm (22 mm decrease since 7:00 on January 19)	—
	Water level of Turbine Building	O.P.+ 2,370 mm (4 mm increase since 7:00 on January 19)	O.P.+ 2,518 mm (15 mm decrease since 7:00 on January 19)	O.P.+ 2,755 mm (39 mm decrease since 7:00 on January 19)	O.P.+ 2,764 mm (13 mm decrease since 7:00 on January 19)
	Water level of Reactor Building	O.P.+ 3,870 mm (11 mm decrease since 7:00 on January 19)	O.P.+ 2,612 mm (10 mm decrease since 7:00 on January 19)	O.P.+ 2,783 mm (45 mm decrease since 7:00 on January 19)	O.P.+ 2,763 mm (8 mm decrease since 7:00 on January 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,163 mm (Increase from initial level:4,380 mm, 245 mm increase since 7:00 on January 19) O.P.+ 1,874 mm (Increase from initial level:2,600 mm, 43 mm decrease since 7:00 on January 19) O.P.+ 4,241 mm (Water level from floor:445 mm, 3 mm increase since 7:00 on January 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:21 on January 18)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on January 19 to 15:00 on January 19)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:19 on January 10 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:35 on January 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.