

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 21)**

Water Level of the accumulated water (at 7:00 on January 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,130 mm (11 mm decrease since 7:00 on January 20)	O.P.+ 2,524 mm (21 mm decrease since 7:00 on January 20)	—
	Water level of Turbine Building	O.P.+ 2,371 mm (1 mm increase since 7:00 on January 20)	O.P.+ 2,507 mm (11 mm decrease since 7:00 on January 20)	O.P.+ 2,721 mm (34 mm decrease since 7:00 on January 20)	O.P.+ 2,748 mm (16 mm decrease since 7:00 on January 20)
	Water level of Reactor Building	O.P.+ 3,850 mm (20 mm decrease since 7:00 on January 20)	O.P.+ 2,593 mm (19 mm decrease since 7:00 on January 20)	O.P.+ 2,748 mm (35 mm decrease since 7:00 on January 20)	O.P.+ 2,749 mm (14 mm decrease since 7:00 on January 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,409 mm (Increase from initial level:4,626 mm, 246 mm increase since 7:00 on January 20) O.P.+ 1,851 mm (Increase from initial level:2,577 mm, 23 mm decrease since 7:00 on January 20) O.P.+ 4,242 mm (Water level from floor:446 mm, 1 mm increase since 7:00 on January 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:21 on January 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:19 on January 10 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:35 on January 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.