

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 23)**

Water Level of the accumulated water (at 7:00 on January 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,122 mm (4 mm decrease since 7:00 on January 22)	O.P.+ 2,485 mm (20 mm decrease since 7:00 on January 22)	—
	Water level of Turbine Building	O.P.+ 2,373 mm (2 mm increase since 7:00 on January 22)	O.P.+ 2,512 mm (9 mm increase since 7:00 on January 22)	O.P.+ 2,673 mm (23 mm decrease since 7:00 on January 22)	O.P.+ 2,711 mm (18 mm decrease since 7:00 on January 22)
	Water level of Reactor Building	O.P.+ 3,829 mm (3 mm decrease since 7:00 on January 22)	O.P.+ 2,610 mm (19 mm increase since 7:00 on January 22)	O.P.+ 2,695 mm (21 mm decrease since 7:00 on January 22)	O.P.+ 2,720 mm (14 mm decrease since 7:00 on January 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,897 mm (Increase from initial level:5,114 mm, 213 mm increase since 7:00 on January 22) O.P.+ 1,660 mm (Increase from initial level:2,386 mm, 75 mm decrease since 7:00 on January 22) O.P.+ 4,251 mm (Water level from floor:455 mm, 4 mm increase since 7:00 on January 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:21 on January 18)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on January 22 to 15:00 on January 22)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:19 on January 10 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:44 on January 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 9:35 AM on January 22, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:19 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 12:44 PM.				

※ For quick publication of the data of water level, values are provided as reference values.