

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 26)**

Water Level of the accumulated water (at 7:00 on January 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,104 mm (6 mm decrease since 7:00 on January 25)	O.P.+ 2,424 mm (20 mm decrease since 7:00 on January 25)	—
	Water level of Turbine Building	O.P.+ 2,377 mm (1 mm increase since 7:00 on January 25)	O.P.+ 2,525 mm (No change since 7:00 on January 25)	O.P.+ 2,600 mm (24 mm decrease since 7:00 on January 25)	O.P.+ 2,651 mm (20 mm decrease since 7:00 on January 25)
	Water level of Reactor Building	O.P.+ 3,790 mm (11 mm decrease since 7:00 on January 25)	O.P.+ 2,607 mm (5 mm increase since 7:00 on January 25)	O.P.+ 2,616 mm (22 mm decrease since 7:00 on January 25)	O.P.+ 2,667 mm (17 mm decrease since 7:00 on January 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,496 mm (Increase from initial level:5,713 mm, 217 mm increase since 7:00 on January 25) O.P.+ 1,213 mm (Increase from initial level:1,939 mm, 143 mm decrease since 7:00 on January 25) O.P.+ 4,259 mm (Water level from floor:463 mm, 6 mm increase since 7:00 on January 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:21 on January 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:19 on January 10   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:44 on January 22   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.