

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 28)**

Water Level of the accumulated water (at 7:00 on January 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,098 mm (3 mm decrease since 7:00 on January 27)	O.P.+ 2,385 mm (19 mm decrease since 7:00 on January 27)	—
	Water level of Turbine Building	O.P.+ 2,378 mm (No change since 7:00 on January 27)	O.P.+ 2,535 mm (5 mm increase since 7:00 on January 27)	O.P.+ 2,558 mm (21 mm decrease since 7:00 on January 27)	O.P.+ 2,611 mm (20 mm decrease since 7:00 on January 27)
	Water level of Reactor Building	O.P.+ 3,789 mm (1 mm increase since 7:00 on January 27)	O.P.+ 2,625 mm (6 mm increase since 7:00 on January 27)	O.P.+ 2,573 mm (22 mm decrease since 7:00 on January 27)	O.P.+ 2,630 mm (19 mm decrease since 7:00 on January 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,633 mm (Increase from initial level:5,850 mm, 32 mm increase since 7:00 on January 27) O.P.+ 1,799 mm (Increase from initial level:2,525 mm, 323 mm increase since 7:00 on January 27) O.P.+ 4,266 mm (Water level from floor:470 mm, 3 mm increase since 7:00 on January 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:21 on January 18)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on January 27 to 15:00 on January 27)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:22 on January 26 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:52 on January 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.