

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 29)**

Water Level of the accumulated water (at 7:00 on January 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,093 mm (5 mm decrease since 7:00 on January 28)	O.P.+ 2,364 mm (21 mm decrease since 7:00 on January 28)	—
	Water level of Turbine Building	O.P.+ 2,379 mm (1 mm increase since 7:00 on January 28)	O.P.+ 2,537 mm (2 mm increase since 7:00 on January 28)	O.P.+ 2,533 mm (25 mm decrease since 7:00 on January 28)	O.P.+ 2,591 mm (20 mm decrease since 7:00 on January 28)
	Water level of Reactor Building	O.P.+ 3,784 mm (5 mm decrease since 7:00 on January 28)	O.P.+ 2,618 mm (7 mm decrease since 7:00 on January 28)	O.P.+ 2,546 mm (27 mm decrease since 7:00 on January 28)	O.P.+ 2,613 mm (17 mm decrease since 7:00 on January 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,666 mm (Increase from initial level:5,883 mm, 33 mm increase since 7:00 on January 28) O.P.+ 2,120 mm (Increase from initial level:2,846 mm, 321 mm increase since 7:00 on January 28) O.P.+ 4,268 mm (Water level from floor:472 mm, 2 mm increase since 7:00 on January 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:21 on January 18)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on January 28 to 15:00 on January 28)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:22 on January 26 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:52 on January 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.