

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 3)**

|   |  |   |   |   |   |
|---|--|---|---|---|---|
| Water Level of the accumulated water<br>(at 7:00 on February 3) |  | Unit 1  | Unit 2  | Unit 3  | Unit 4  |
|   | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)   | O.P.+ 2,096 mm<br>(1 mm decrease since 7:00 on February 2)  | O.P.+ 2,348 mm<br>(21 mm decrease since 7:00 on February 2)   | —   |
|   | Water level of Turbine Building  | O.P.+ 2,388 mm<br>(3 mm increase since 7:00 on February 2)  | O.P.+ 2,561 mm<br>(4 mm increase since 7:00 on February 2)  | O.P.+ 2,538 mm<br>(34 mm decrease since 7:00 on February 2)   | O.P.+ 2,563 mm<br>(10 mm decrease since 7:00 on February 2) |
|   | Water level of Reactor Building  | O.P.+ 3,831 mm<br>(7 mm increase since 7:00 on February 2)  | O.P.+ 2,649 mm<br>(No change since 7:00 on February 2)  | O.P.+ 2,549 mm<br>(39 mm decrease since 7:00 on February 2)   | O.P.+ 2,583 mm<br>(8 mm decrease since 7:00 on February 2)  |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building   | O.P.+ 4,407 mm (Increase from initial level:5,624 mm, 44 mm increase since 7:00 on February 2)<br>O.P.+ 1,581 mm (Increase from initial level:2,307 mm, 121 mm decrease since 7:00 on February 2)<br>O.P.+ 4,284 mm (Water level from floor:488 mm, 3 mm increase since 7:00 on February 2) |   |   |
| Situation of transfer of the accumulated water                  |  | Unit 1  | Unit 2  | Unit 3  | Unit 4  |
|   |  | —   | Basement of Unit 2 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred<br>(Since 9:58 on December 22)  | Basement of Unit 3 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (Process Main Building)<br>Currently being transferred<br>(Since 9:56 on February 1) | —   |
|   |  | Unit 5 and 6  |   |   |   |
|   |  | Basement of Unit 6 Turbine Building<br>→Temporary Tank<br>Transfer Completed<br>(From 10:00 on February 2 to 15:00 on February 2)   |   |   |   |
| Operation condition of water treatment facility                 |  | Cesium Adsorption Apparatus: Since 16:22 on January 26 In operation<br>2nd Cesium Adsorption Apparatus (Sarry): Since 13:30 on January 29 In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |   |   |   |
| Notes   |  |   |   |   |   |

※ For quick publication of the data of water level, values are provided as reference values.