

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 4)**

Water Level of the accumulated water (at 7:00 on February 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,095 mm (1 mm decrease since 7:00 on February 3)	O.P.+ 2,330 mm (18 mm decrease since 7:00 on February 3)	—
	Water level of Turbine Building	O.P.+ 2,392 mm (4 mm increase since 7:00 on February 3)	O.P.+ 2,564 mm (3 mm increase since 7:00 on February 3)	O.P.+ 2,510 mm (28 mm decrease since 7:00 on February 3)	O.P.+ 2,549 mm (14 mm decrease since 7:00 on February 3)
	Water level of Reactor Building	O.P.+ 3,837 mm (6 mm increase since 7:00 on February 3)	O.P.+ 2,655 mm (6 mm increase since 7:00 on February 3)	O.P.+ 2,517 mm (32 mm decrease since 7:00 on February 3)	O.P.+ 2,571 mm (12 mm decrease since 7:00 on February 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,475 mm (Increase from initial level:5,692 mm, 68 mm increase since 7:00 on February 3) O.P.+ 1,467 mm (Increase from initial level:2,193 mm, 114 mm decrease since 7:00 on February 3) O.P.+ 4,287 mm (Water level from floor:491 mm, 3 mm increase since 7:00 on February 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:56 on February 1)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:22 on January 26 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:30 on January 29 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.