

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 6)**

Water Level of the accumulated water (at 7:00 on February 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,093 mm (No change since 7:00 on February 5)	O.P.+ 2,332 mm (16 mm increase since 7:00 on February 5)	—
	Water level of Turbine Building	O.P.+ 2,398 mm (3 mm increase since 7:00 on February 5)	O.P.+ 2,574 mm (4 mm increase since 7:00 on February 5)	O.P.+ 2,490 mm (7 mm decrease since 7:00 on February 5)	O.P.+ 2,529 mm (6 mm decrease since 7:00 on February 5)
	Water level of Reactor Building	O.P.+ 3,854 mm (8 mm increase since 7:00 on February 5)	O.P.+ 2,670 mm (9 mm increase since 7:00 on February 5)	O.P.+ 2,498 mm (10 mm decrease since 7:00 on February 5)	O.P.+ 2,553 mm (6 mm decrease since 7:00 on February 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,554 mm (Increase from initial level:5,771 mm, 40 mm increase since 7:00 on February 5) O.P.+ 1,704 mm (Increase from initial level:2,430 mm, 340 mm increase since 7:00 on February 5) O.P.+ 4,294 mm (Water level from floor:498 mm, 3 mm increase since 7:00 on February 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 9:56 on February 1 to 6:13 on February 6)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed	(From 10:00 on February 5 to 15:00 on February 5)
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:22 on January 26 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:32 on February 5 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.