

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 9)**

Water Level of the accumulated water (at 7:00 on February 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,092 mm (3 mm increase since 7:00 on February 8)	O.P.+ 2,438 mm (20 mm increase since 7:00 on February 8)	—
	Water level of Turbine Building	O.P.+ 2,403 mm (2 mm increase since 7:00 on February 8)	O.P.+ 2,591 mm (10 mm increase since 7:00 on February 8)	O.P.+ 2,603 mm (22 mm increase since 7:00 on February 8)	O.P.+ 2,554 mm (15 mm increase since 7:00 on February 8)
	Water level of Reactor Building	O.P.+ 3,877 mm (19 mm increase since 7:00 on February 8)	O.P.+ 2,696 mm (20 mm increase since 7:00 on February 8)	O.P.+ 2,617 mm (26 mm increase since 7:00 on February 8)	O.P.+ 2,569 mm (13 mm increase since 7:00 on February 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,111 mm (Increase from initial level:5,328 mm, 145 mm decrease since 7:00 on February 8) O.P.+ 2,685 mm (Increase from initial level:3,411 mm, 318 mm increase since 7:00 on February 8) O.P.+ 4,302 mm (Water level from floor:506 mm, 4 mm increase since 7:00 on February 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:58 on December 22)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:50 on February 7 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:32 on February 5 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.