

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 10)**

Water Level of the accumulated water (at 7:00 on February 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,093 mm (1 mm increase since 7:00 on February 9)	O.P.+ 2,441 mm (3 mm increase since 7:00 on February 9)	—
	Water level of Turbine Building	O.P.+ 2,407 mm (4 mm increase since 7:00 on February 9)	O.P.+ 2,590 mm (1 mm decrease since 7:00 on February 9)	O.P.+ 2,604 mm (1 mm increase since 7:00 on February 9)	O.P.+ 2,566 mm (12 mm increase since 7:00 on February 9)
	Water level of Reactor Building	O.P.+ 3,888 mm (11 mm increase since 7:00 on February 9)	O.P.+ 2,688 mm (8 mm decrease since 7:00 on February 9)	O.P.+ 2,620 mm (3 mm increase since 7:00 on February 9)	O.P.+ 2,579 mm (10 mm increase since 7:00 on February 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,125 mm (Increase from initial level:5,342 mm, 14 mm increase since 7:00 on February 9) O.P.+ 2,758 mm (Increase from initial level:3,484 mm, 73 mm increase since 7:00 on February 9) O.P.+ 4,304 mm (Water level from floor:508 mm, 2 mm increase since 7:00 on February 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:51 on February 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:41 on February 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:50 on February 7 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:32 on February 5 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.