

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 16)**

Water Level of the accumulated water (at 7:00 on February 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,105 mm (3 mm increase since 7:00 on February 15)	O.P.+ 2,465 mm (1 mm increase since 7:00 on February 15)	—
	Water level of Turbine Building	O.P.+ 2,426 mm (2 mm increase since 7:00 on February 15)	O.P.+ 2,533 mm (49 mm decrease since 7:00 on February 15)	O.P.+ 2,571 mm (65 mm increase since 7:00 on February 15)	O.P.+ 2,550 mm (15 mm decrease since 7:00 on February 15)
	Water level of Reactor Building	O.P.+ 3,879 mm (18 mm decrease since 7:00 on February 15)	O.P.+ 2,656 mm (34 mm decrease since 7:00 on February 15)	O.P.+ 2,581 mm (66 mm increase since 7:00 on February 15)	O.P.+ 2,567 mm (16 mm decrease since 7:00 on February 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,461 mm (Increase from initial level:5,678 mm, 102 mm increase since 7:00 on February 15) O.P.+ 2,448 mm (Increase from initial level:3,174 mm, 390 mm decrease since 7:00 on February 15) O.P.+ 4,317 mm (Water level from floor:521 mm, 2 mm increase since 7:00 on February 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on February 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:41 on February 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:58 on February 15 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:24 on February 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.