

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 17)**

Water Level of the accumulated water (at 7:00 on February 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,109 mm (4 mm increase since 7:00 on February 16)	O.P.+ 2,486 mm (21 mm increase since 7:00 on February 16)	—
	Water level of Turbine Building	O.P.+ 2,426 mm (No change since 7:00 on February 16)	O.P.+ 2,488 mm (45 mm decrease since 7:00 on February 16)	O.P.+ 2,610 mm (39 mm increase since 7:00 on February 16)	O.P.+ 2,562 mm (12 mm increase since 7:00 on February 16)
	Water level of Reactor Building	O.P.+ 3,853 mm (26 mm decrease since 7:00 on February 16)	O.P.+ 2,610 mm (46 mm decrease since 7:00 on February 16)	O.P.+ 2,626 mm (45 mm increase since 7:00 on February 16)	O.P.+ 2,576 mm (9 mm increase since 7:00 on February 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,512 mm (Increase from initial level:5,729 mm, 51 mm increase since 7:00 on February 16) O.P.+ 2,021 mm (Increase from initial level:2,747 mm, 427 mm decrease since 7:00 on February 16) O.P.+ 4,318 mm (Water level from floor:522 mm, 1 mm increase since 7:00 on February 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on February 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:41 on February 9)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on February 16 to 15:00 on February 16)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:58 on February 15 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:24 on February 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.