

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 19)**

Water Level of the accumulated water (at 7:00 on February 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,144 mm (31 mm increase since 7:00 on February 18)	O.P.+ 2,484 mm (13 mm increase since 7:00 on February 18)	—
	Water level of Turbine Building	O.P.+ 2,431 mm (4 mm increase since 7:00 on February 18)	O.P.+ 2,479 mm (2 mm decrease since 7:00 on February 18)	O.P.+ 2,552 mm (16 mm decrease since 7:00 on February 18)	O.P.+ 2,565 mm (No change since 7:00 on February 18)
	Water level of Reactor Building	O.P.+ 3,890 mm (75 mm increase since 7:00 on February 18)	O.P.+ 2,610 mm (18 mm increase since 7:00 on February 18)	O.P.+ 2,567 mm (21 mm decrease since 7:00 on February 18)	O.P.+ 2,580 mm (No change since 7:00 on February 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,633 mm (Increase from initial level:5,850 mm, 62 mm increase since 7:00 on February 18) O.P.+ 2,002 mm (Increase from initial level:2,728 mm, 27 mm increase since 7:00 on February 18) O.P.+ 4,325 mm (Water level from floor:529 mm, 4 mm increase since 7:00 on February 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:57 on February 17)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:41 on February 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:58 on February 15 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:24 on February 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.