

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 20)**

Water Level of the accumulated water (at 7:00 on February 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,138 mm (6 mm decrease since 7:00 on February 19)	O.P.+ 2,514 mm (30 mm increase since 7:00 on February 19)	—
	Water level of Turbine Building	O.P.+ 2,445 mm (14 mm increase since 7:00 on February 19)	O.P.+ 2,552 mm (73 mm increase since 7:00 on February 19)	O.P.+ 2,532 mm (20 mm decrease since 7:00 on February 19)	O.P.+ 2,563 mm (2 mm decrease since 7:00 on February 19)
	Water level of Reactor Building	O.P.+ 3,925 mm (35 mm increase since 7:00 on February 19)	O.P.+ 2,630 mm (20 mm increase since 7:00 on February 19)	O.P.+ 2,541 mm (26 mm decrease since 7:00 on February 19)	O.P.+ 2,579 mm (1 mm decrease since 7:00 on February 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,687 mm (Increase from initial level:5,904 mm, 54 mm increase since 7:00 on February 19) O.P.+ 2,079 mm (Increase from initial level:2,805 mm, 77 mm increase since 7:00 on February 19) O.P.+ 4,329 mm (Water level from floor:533 mm, 4 mm increase since 7:00 on February 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:57 on February 17 to 10:11 on February 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:41 on February 9)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on February 19 to 15:00 on February 19)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:58 on February 15 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:25 on February 19 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.