

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 21)**

Water Level of the accumulated water (at 7:00 on February 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,129 mm (9 mm decrease since 7:00 on February 20)	O.P.+ 2,528 mm (14 mm increase since 7:00 on February 20)	—
	Water level of Turbine Building	O.P.+ 2,455 mm (10 mm increase since 7:00 on February 20)	O.P.+ 2,622 mm (70 mm increase since 7:00 on February 20)	O.P.+ 2,513 mm (19 mm decrease since 7:00 on February 20)	O.P.+ 2,556 mm (7 mm decrease since 7:00 on February 20)
	Water level of Reactor Building	O.P.+ 3,947 mm (22 mm increase since 7:00 on February 20)	O.P.+ 2,689 mm (59 mm increase since 7:00 on February 20)	O.P.+ 2,520 mm (21 mm decrease since 7:00 on February 20)	O.P.+ 2,574 mm (5 mm decrease since 7:00 on February 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,770 mm (Increase from initial level:5,987 mm, 83 mm increase since 7:00 on February 20) O.P.+ 2,087 mm (Increase from initial level:2,813 mm, 8 mm increase since 7:00 on February 20) O.P.+ 4,331 mm (Water level from floor:535 mm, 2 mm increase since 7:00 on February 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:41 on February 9)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on February 20 to 15:00 on February 20)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 17:44 on February 20 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:25 on February 19 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.