

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 22)**

Water Level of the accumulated water (at 7:00 on February 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,122 mm (7 mm decrease since 7:00 on February 21)	O.P.+ 2,519 mm (9 mm decrease since 7:00 on February 21)	—
	Water level of Turbine Building	O.P.+ 2,465 mm (10 mm increase since 7:00 on February 21)	O.P.+ 2,685 mm (63 mm increase since 7:00 on February 21)	O.P.+ 2,565 mm (52 mm increase since 7:00 on February 21)	O.P.+ 2,545 mm (11 mm decrease since 7:00 on February 21)
	Water level of Reactor Building	O.P.+ 3,965 mm (18 mm increase since 7:00 on February 21)	O.P.+ 2,753 mm (64 mm increase since 7:00 on February 21)	O.P.+ 2,574 mm (54 mm increase since 7:00 on February 21)	O.P.+ 2,563 mm (11 mm decrease since 7:00 on February 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,634 mm (Increase from initial level:5,851 mm, 136 mm decrease since 7:00 on February 21) O.P.+ 2,090 mm (Increase from initial level:2,816 mm, 3 mm increase since 7:00 on February 21) O.P.+ 4,332 mm (Water level from floor:536 mm, 1 mm increase since 7:00 on February 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 10:41 on February 9 to 9:53 on February 21)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 17:44 on February 20 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:25 on February 19 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.