

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 23)**

Water Level of the accumulated water (at 7:00 on February 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,117 mm (5 mm decrease since 7:00 on February 22)	O.P.+ 2,526 mm (7 mm increase since 7:00 on February 22)	—
	Water level of Turbine Building	O.P.+ 2,475 mm (10 mm increase since 7:00 on February 22)	O.P.+ 2,742 mm (57 mm increase since 7:00 on February 22)	O.P.+ 2,597 mm (32 mm increase since 7:00 on February 22)	O.P.+ 2,554 mm (9 mm increase since 7:00 on February 22)
	Water level of Reactor Building	O.P.+ 4,000 mm (35 mm increase since 7:00 on February 22)	O.P.+ 2,822 mm (69 mm increase since 7:00 on February 22)	O.P.+ 2,611 mm (37 mm increase since 7:00 on February 22)	O.P.+ 2,568 mm (5 mm increase since 7:00 on February 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,454 mm (Increase from initial level:5,671 mm, 180 mm decrease since 7:00 on February 22) O.P.+ 2,092 mm (Increase from initial level:2,818 mm, 2 mm increase since 7:00 on February 22) O.P.+ 4,335 mm (Water level from floor:539 mm, 3 mm increase since 7:00 on February 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 17:44 on February 20 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:25 on February 19 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.